Bradlev


269-1444 Eye and Eye/Face Wash Pattern Test Gauge

- Transparent Compliance Gauge Facilitates Weekly Inspection
- Testing Instructions Printed on Test Gauge
- Integral 8" (21cm) Scale Assists in Evaluation of Spray Pattern Height
- Spray Pattern Focal Points Easy to Align
- Illustration Compliant With American National Standard Z358.1-2009

Specifications

Clear plastic 8" (21cm) ruler stamped with black text instructs how to test the eye or eye/face wash system. Text refers to ANSI Z358.1-2009 testing protocols to ensure that the emergency system complies with the standard's recommendations and is fully functional as intended by the manufacturer.

Model	Description
□ 269-1444	Eye and Eye/Face Wash Pattern Test Gauge



Emergency Fixtures Document No. 4976

Page 1 of 1 This information is subject to change without notice. 11/11/10

© 2012 Bradley P.O. Box 309, Menomonee Falls, WI 53052-0309 Phone: 800.BRADLEY (800.272.3539) Fax: 262.251.5817 bradleycorp.com

top of sprayhead(s)